



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 10-02133  
Inspection Number: 02848932

## Building Inspection Report

Code Reviewed Under: 2006 IRC

### Permit Information

**Job Address:** 6278 OXFORD PEAK PL CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Basement  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 08/31/2010  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Approved  
**Inspected By:** Wayne Elmore  
**Charge Reinspection Fee:** No