



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 10-07659

Inspection Number: 02862403

Building Inspection Report

Code Reviewed Under: 2006 IBC

Permit Information

Job Address: 8361 N RAMPART RANGE RD # B208, LITTLETON

Job Type: Building

Description: CM - Tenant Finish

Scope of Work: New

Inspection Details

Inspection Date: 12/06/2010

Inspection Time: 12:00 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Approved

Inspected By: Jim Dorsey

Charge Reinspection Fee: No