Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 11-04527
Inspection Number: 02894089

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 10044 DEER CREEK ST HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 08/19/2011
Inspection Time: 12:00 AM
Inspection Type: Insulation Thermal
Inspection Code: 36
Outcome: Disapproved
Inspected By: Courtney Arford
Charge Reinspection Fee: No

Comments

complete mb