



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 11-06119
Inspection Number: 02913580

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 11561 WARRINGTON CT PARKER
Job Type: Building
Description: AU - Garage
Scope of Work: Addition

Inspection Details

Inspection Date: 01/05/2012
Inspection Time: 12:00 AM
Inspection Type: Drip Edge
Inspection Code: 58
Outcome: Approved
Inspected By: Rich Garrett
Charge Reinspection Fee: No