



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 12-00082  
Inspection Number: 02915004

## Building Inspection Report

Code Reviewed Under: 2006 IRC

### Permit Information

**Job Address:** 5519 IRISH PAT MURPHY DR PARKER  
**Job Type:** Building  
**Description:** RS - Basement  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 01/18/2012  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Rough Frame  
**Inspection Code:** 29  
**Outcome:** Approved  
**Inspected By:** Rich Garrett  
**Charge Reinspection Fee:** No