DOUGLAS COUNTY
BUILDING DIVISION COLORADO

Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 12-00082
Inspection Number: 02917986

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 5519 IRISH PAT MURPHY DR PARKER
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 02/13/2012
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

1) Microwave receptacle must be GFCI protected (within 6' of sink)
2) Same as #1 @ refrigerator
3) Provide access to recept @ ejector pump under sink (See#1&2)
4) Support both sides of subpanel