



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 12-00082  
Inspection Number: 02917986

## Building Inspection Report

Code Reviewed Under: 2006 IRC

### Permit Information

**Job Address:** 5519 IRISH PAT MURPHY DR PARKER  
**Job Type:** Building  
**Description:** RS - Basement  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 02/13/2012  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Rich Edgett  
**Charge Reinspection Fee:** No

### Comments

- 1) Microwave receptacle must be GFCI protected (within 6' of sink)
- 2) Same as #1 @ refrigerator
- 3) Provide access to recept @ ejector pump under sink (See#1&2)
- 4) Support both sides of subpanel