Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 12-00082
Inspection Number: 02917988

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 5519 IRISH PAT MURPHY DR PARKER
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 02/13/2012
Inspection Time: 12:00 AM
Inspection Type: Final Plumbing
Inspection Code: 40
Outcome: Approved
Inspected By: Rich Garrett
Charge Reinspection Fee: No