



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 11-05714
Inspection Number: 02921774

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 2590 ANNIES PL CASTLE ROCK
Job Type: Building
Description: AU - Garage
Scope of Work: New

Inspection Details

Inspection Date: 03/09/2012
Inspection Time: 12:00 AM
Inspection Type: Rough Plumbing
Inspection Code: 28
Outcome: Approved
Inspected By: Kerry Keller
Charge Reinspection Fee: No