



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 12-01160

Inspection Number: 02925324

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 3529 MALLARD DR HIGHLANDS RANCH

Job Type: Building

Description: RS - Residential

Scope of Work: Alteration

Inspection Details

Inspection Date: 03/30/2012

Inspection Time: 12:00 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Approved

Inspected By: Rick Sugar

Charge Reinspection Fee: No

Comments

NOTE no more than 4 openings serving the counter top