



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 11-05714  
Inspection Number: 02931578

## Building Inspection Report

Code Reviewed Under: 2006 IRC

### Permit Information

Job Address: 2590 ANNIES PL CASTLE ROCK  
Job Type: Building  
Description: AU - Garage  
Scope of Work: New

### Inspection Details

Inspection Date: 05/04/2012  
Inspection Time: 12:00 AM  
Inspection Type: Final Grade  
Inspection Code: 62  
Outcome: Disapproved  
Inspected By: Jerry Dortch  
Charge Reinspection Fee: No

### Comments

See ticket.