Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 12-05356
Inspection Number: 02944436

Building Inspection Report

Permit Information

Job Address: 6745 LIONSHEAD PKWY LITTLETON
Job Type: Roofing
Description: Composition -

Inspection Details

Inspection Date: 07/16/2012
Inspection Time: 12:00 AM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Disapproved
Inspected By: Courtney Arford
Charge Reinspection Fee: No

Comments

felt goes over drip edge @ eaves
all eaves require drip edge
realace damaged shingles