



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 12-05356  
Inspection Number: 02944436

## Building Inspection Report

### Permit Information

**Job Address:** 6745 LIONSHEAD PKWY LITTLETON  
**Job Type:** Roofing  
**Description:** Composition -

### Inspection Details

**Inspection Date:** 07/16/2012  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Roofing  
**Inspection Code:** 34  
**Outcome:** Disapproved  
**Inspected By:** Courtney Arford  
**Charge Reinspection Fee:** No

### Comments

felt goes over drip edge @ eaves  
all eaves require drip edge  
realace damaged shingles