



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 12-05137
Inspection Number: 02945811

Building Inspection Report

Permit Information

Job Address: 135 STAGHORN WAY FRANKTOWN
Job Type: Roofing
Description: Composition -

Inspection Details

Inspection Date: 07/20/2012
Inspection Time: 12:00 AM
Inspection Type: Midroof
Inspection Code: 60
Outcome: Disapproved
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

not ready