



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 12-07333
Inspection Number: 02951101

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 9381 CORRAL LN CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 08/09/2012
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

- 1) Receptacle box below microwave overfilled
- 2) Staple nm cables 1-1/4" from studface
- 3) Recept @ left of window overfilled
- 4) Add 120V recept for range
- 5) Add recept @ wall side of peninsula