



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 12-07333  
Inspection Number: 02951103

## Building Inspection Report

Code Reviewed Under: 2006 IRC

### Permit Information

**Job Address:** 9381 CORRAL LN CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 08/09/2012  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Rough Frame  
**Inspection Code:** 29  
**Outcome:** Disapproved  
**Inspected By:** Rick Chadwick  
**Charge Reinspection Fee:** No

### Comments

COMPLETE PLUMBING FOR KIT  
OK TO REINSTALL INS AND DRYWALL PPER ELEC INSP