



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 11-06950  
Inspection Number: 02951117

## Building Inspection Report

Code Reviewed Under: 2006 IRC

### Permit Information

Job Address: 4332 CHATEAU RIDGE RD CASTLE ROCK  
Job Type: Building  
Description: RS - Master Plan  
Scope of Work: New

### Inspection Details

Inspection Date: 08/09/2012  
Inspection Time: 12:00 AM  
Inspection Type: Insulation Thermal  
Inspection Code: 36  
Outcome: Disapproved  
Inspected By: Kerry Keller  
Charge Reinspection Fee: No

### Comments

1- need to install air barrier at DBL wall bsmt and shower set master