



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 11-06950
Inspection Number: 02951615

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 4332 CHATEAU RIDGE RD CASTLE ROCK
Job Type: Building
Description: RS - Master Plan
Scope of Work: New

Inspection Details

Inspection Date: 08/13/2012
Inspection Time: 7:40 AM
Inspection Type: Electric Trench
Inspection Code: 16
Outcome: Cancelled
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

Per MJ