



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 12-06027  
Inspection Number: 02961576

## Building Inspection Report

Code Reviewed Under: 2006 IRC

### Permit Information

**Job Address:** 506 FOX HUNT CIR HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** AU - Deck  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 09/07/2012  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Building  
**Inspection Code:** 108  
**Outcome:** Approved  
**Inspected By:** Brian Brown  
**Charge Reinspection Fee:** No