



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 12-15176
Inspection Number: 02980455

Building Inspection Report

Permit Information

Job Address: 10333 FAIRLAWN TRL HIGHLANDS RANCH
Job Type: Roofing
Description: Composition -

Inspection Details

Inspection Date: 10/30/2012
Inspection Time: 12:00 AM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Disapproved
Inspected By: Jerry Hammerton
Charge Reinspection Fee: No

Comments

#1 seal soffit and fascia where they intersect roof, lower level RH side. #2 seal beauty course. #3 clear off roof debris on north side (there's alot of it)