



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 12-06249
Inspection Number: 02984627

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 467 DEER MEADOW LN LITTLETON
Job Type: Building
Description: AU - Barn
Scope of Work: New

Inspection Details

Inspection Date: 11/08/2012
Inspection Time: 12:00 AM
Inspection Type: Rough Plumbing
Inspection Code: 28
Outcome: Approved
Inspected By: Courtney Arford
Charge Reinspection Fee: No