



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 12-06249
Inspection Number: 02995107

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 467 DEER MEADOW LN LITTLETON
Job Type: Building
Description: AU - Barn
Scope of Work: New

Inspection Details

Inspection Date: 12/10/2012
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Rick Sugar
Charge Reinspection Fee: No

Comments

Ufer must be accessible as noted on 11/8/12