Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 13-01047
Inspection Number: 03009106

Building Inspection Report

Permit Information

Job Address: 9360 TAMMY LN PARKER
Job Type: Electrical
Description: Other - ADD SEPARATE METER

Inspection Details

Inspection Date: 02/21/2013
Inspection Time: 12:00 AM
Inspection Type: Electric Service Equipment
Inspection Code: 23
Meter Release: Yes
Provider: IREA
Outcome: Approved
Inspected By: Wayne Elmore
Charge Reinspection Fee: No