



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-00155
Inspection Number: 03009406

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 3529 MALLARD DR HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 02/22/2013
Inspection Time: 12:00 AM
Inspection Type: Shower Pan
Inspection Code: 65
Outcome: Approved
Inspected By: Courtney Arford
Charge Reinspection Fee: No