



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-00155

Inspection Number: 03009947

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 3529 MALLARD DR HIGHLANDS RANCH

Job Type: Building

Description: RS - Residential

Scope of Work: Alteration

Inspection Details

Inspection Date: 02/27/2013

Inspection Time: 12:00 AM

Inspection Type: Drywall

Inspection Code: 38

Outcome: Approved

Inspected By: Jerry Hammerton

Charge Reinspection Fee: No

Comments

10-12