



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 12-15016
Inspection Number: 03010575

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 4334 CHATEAU RIDGE RD CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 03/05/2013
Inspection Time: 3:10 PM
Inspection Type: Roof Truss
Inspection Code: 127
Outcome: Cancelled
Inspected By: Kerry Keller
Charge Reinspection Fee: No