



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 13-00150

Inspection Number: 03012491

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 9534 S HACKBERRY ST HIGHLANDS RANCH

**Job Type:** Building

**Description:** RS - Basement

**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 03/15/2013

**Inspection Time:** 12:00 AM

**Inspection Type:** Final Electric

**Inspection Code:** 42

**Outcome:** Disapproved

**Inspected By:** Rick Sugar

**Charge Reinspection Fee:** No

### Comments

- 1)Secure receptacles @ crawl space wall & left of excecise rm door
- 2)GFCI within 6' of wetbar sink
- 3)ARC fault wetbar circuits
- 4)ARC fault existing circuit (5 recessed Its added)
- 5)6' rule at wetbar knee wall