



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 12-15016
Inspection Number: 03014225

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 4334 CHATEAU RIDGE RD CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 03/25/2013
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

- 1) Fire Dept approval required
 - 2) Service is NOT to be energized until after inspection
 - 3) Install p-ring @ mstr bath floor heat
 - 4) 4AWG SER @ mstr vanity??
 - 5) Recept @ right of sliding glass door in mstr bdrm is over 6"
 - 6) Additional recept may be required @ front grade level
 - 7) Elect. box in hall by laundry (up high) is not wired
 - 8) PEX clearance to canlights
 - 9) GEC to plastic water pipe???
 - 10) Bond Cu sprinkler pipe in unfinished bsmnt
 - 11) Sprinkler pipe incomplete
 - 12) Box in bsmnt unfinished ceiling near I-beam is not wired
- NOTE: 2 j-boxes in cabinet @ left of Range