



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 12-15016
Inspection Number: 03014687

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 4334 CHATEAU RIDGE RD CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 03/27/2013
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

1) Add receipts @ bar tops in bsmnt
2) PEX clearance to canlight in bsmnt shower
NOTE: Speaker prewires in ceiling are NOT boxed
OK to insulate pending Frame approval