



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 12-15018
Inspection Number: 03014688

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 4336 CHATEAU RIDGE RD CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 03/27/2013
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

NOTES:

- a) Sprinkler pipe bonding incomplete (Under Stairs)
- b) No p-ring @ 4-sqr box in master bath
- c) 2 J-boxes in cabinet @ ovens