



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-01986
Inspection Number: 03017905

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 10268 BENTWOOD LN HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 04/12/2013
Inspection Time: 7:34 AM
Inspection Type: Rough HVAC
Inspection Code: 27
Outcome: Approved
Inspected By: Clayton Rodeback
Charge Reinspection Fee: No