



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-01986

Inspection Number: 03023922

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 10268 BENTWOOD LN HIGHLANDS RANCH

Job Type: Building

Description: RS - Basement

Scope of Work: Alteration

Inspection Details

Inspection Date: 05/15/2013

Inspection Time: 12:00 AM

Inspection Type: Final Building

Inspection Code: 108

Outcome: Disapproved

Inspected By: Jerry Hammerton

Charge Reinspection Fee: No

Comments

1) CO detectors w/ in 15' of all sleeping rooms. 2) Min. 100 sq in RA rq'd.