



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 12-18307
Inspection Number: 03034159

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 4338 CHATEAU RIDGE RD CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 07/03/2013
Inspection Time: 12:00 AM
Inspection Type: Electric Trench
Inspection Code: 16
Outcome: Disapproved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

- 1) EGC required in trench with feeders
- 2) Install plastic bushing @ end of PVC underground