

Douglas County Building Division 100 Third Street STE #20 Castle Rock, CO 80104 Phone: 303.660.7497

Email: dcbuilding@douglas.co.us

Permit Number: 12-18311 Inspection Number: 03035661

## **Building Inspection Report**

Code Reviewed Under: 2006 IRC

## **Permit Information**

Job Address: 4340 CHATEAU RIDGE RD CASTLE ROCK

Job Type: Building
Description: RS - Duplex
Scope of Work: New

## **Inspection Details**

Inspection Date: 07/12/2013 Inspection Time: 12:00 AM

Inspection Type: Insulation Thermal

Inspection Code: 36
Outcome: Disapproved
Inspected By: Kerry Keller
Charge Reinspection Fee: No

## Comments

1- Need to complete air barrier at right side of main floor place,BSMT fured walls and sump pit chase. ok to start drywall keep off items above