



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 12-18307  
Inspection Number: 03035715

## Building Inspection Report

Code Reviewed Under: 2006 IRC

### Permit Information

**Job Address:** 4338 CHATEAU RIDGE RD CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Duplex  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 07/12/2013  
**Inspection Time:** 3:10 PM  
**Inspection Type:** Exterior Lath  
**Inspection Code:** 33  
**Outcome:** Cancelled  
**Inspected By:** Kerry Keller  
**Charge Reinspection Fee:** No

### Comments

Cancelled by office