



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 12-18311  
Inspection Number: 03037887

## Building Inspection Report

Code Reviewed Under: 2006 IRC

### Permit Information

**Job Address:** 4340 CHATEAU RIDGE RD CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Duplex  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 07/24/2013  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Moisture Barrier  
**Inspection Code:** 53  
**Outcome:** Disapproved  
**Inspected By:** Rick Chadwick  
**Charge Reinspection Fee:** No

### Comments

NOT READY