



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 12-18307  
Inspection Number: 03037891

## Building Inspection Report

Code Reviewed Under: 2006 IRC

### Permit Information

Job Address: 4338 CHATEAU RIDGE RD CASTLE ROCK  
Job Type: Building  
Description: RS - Duplex  
Scope of Work: New

### Inspection Details

Inspection Date: 07/24/2013  
Inspection Time: 12:00 AM  
Inspection Type: Moisture Barrier  
Inspection Code: 53  
Outcome: Disapproved  
Inspected By: Rick Chadwick  
Charge Reinspection Fee: No

### Comments

NOT READY