



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 12-18311
Inspection Number: 03039300

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 4340 CHATEAU RIDGE RD CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 08/01/2013
Inspection Time: 12:00 AM
Inspection Type: Moisture Barrier
Inspection Code: 53
Outcome: Disapproved
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

1-still installing, not ready