



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: [dcbuilding@douglasco.gov](mailto:dcbuilding@douglasco.gov)

Permit Number: 13-02362  
Inspection Number: 03043329

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 5044 VERMILLION DR CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Stock  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 08/26/2013  
**Inspection Time:** 7:34 AM  
**Inspection Type:** Rough Plumbing  
**Inspection Code:** 28  
**Outcome:** Cancelled  
**Inspected By:** Kerry Keller  
**Charge Reinspection Fee:** No