



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 12-18311  
Inspection Number: 03044628

## Building Inspection Report

Code Reviewed Under: 2006 IRC

### Permit Information

Job Address: 4340 CHATEAU RIDGE RD CASTLE ROCK  
Job Type: Building  
Description: RS - Duplex  
Scope of Work: New

### Inspection Details

Inspection Date: 08/30/2013  
Inspection Time: 8:37 AM  
Inspection Type: Final Electric  
Inspection Code: 42  
Outcome: Cancelled  
Inspected By: Rich Edgett  
Charge Reinspection Fee: No

### Comments

Per Troy