



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 12-18311
Inspection Number: 03046279

Building Inspection Report

Code Reviewed Under: 2006 IRC

Permit Information

Job Address: 4340 CHATEAU RIDGE RD CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 09/10/2013
Inspection Time: 7:54 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Cancelled
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

Approved 9-9-13 RE