



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-02444
Inspection Number: 03047799

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 4374 CHATEAU RIDGE LN CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 09/18/2013
Inspection Time: 12:00 AM
Inspection Type: Roof Truss
Inspection Code: 127
Outcome: Disapproved
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

1-Cannot have lat, brace's angling across web's must be the same web's design's
2- missing lat, bracing see truss details for correction