



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 13-02364
Inspection Number: 03050182

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5030 BALLARAT LN CASTLE ROCK
Job Type: Building
Description: RS - Master Plan
Scope of Work: New

Inspection Details

Inspection Date: 10/02/2013
Inspection Time: 2:30 PM
Inspection Type: Insulation Thermal
Inspection Code: 36
Outcome: Cancelled
Inspected By: Jerry Hammerton
Charge Reinspection Fee: No

Comments

Already done