



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-02444
Inspection Number: 03053018

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 4374 CHATEAU RIDGE LN CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 10/17/2013
Inspection Time: 7:11 AM
Inspection Type: Rough HVAC Partial
Inspection Code: 25
Outcome: Cancelled
Inspected By: Rick Chadwick
Charge Reinspection Fee: No