Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 13-07264
Inspection Number: 03054936

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 9121 FOX FIRE DR HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 10/25/2013
Inspection Time: 12:00 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Disapproved
Inspected By: Clayton Rodeback
Charge Reinspection Fee: No

Comments

Fasten shower mixer valve to the framing.
Iinstall bathroom exhaust fan and rough in exhaust duct.
Install nail plates at copper supply lines for bath lav. (Top plate at both sides)