

Douglas County Building Division 100 Third Street STE #20 Castle Rock, CO 80104 Phone: 303.660.7497 Email: dcbuilding@douglas.co.us

> Permit Number: 13-07264 Inspection Number: 03054936

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 9121 FOX FIRE DR HIGHLANDS RANCH Job Type: Building Description: RS - Basement Scope of Work: Alteration

Inspection Details

Inspection Date: 10/25/2013 Inspection Time: 12:00 AM Inspection Type: Rough Frame Inspection Code: 29 Outcome: Disapproved Inspected By: Clayton Rodeback Charge Reinspection Fee: No

Comments

Fasten shower mixer valve to the framing. Iinstall bathroom exhaust fan and rough in exhaust duct. Install nail plates at copper supply lines for bath lav. (Top plate at both sides)