



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 13-02362
Inspection Number: 03055720

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5044 VERMILLION DR CASTLE ROCK
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 10/30/2013
Inspection Time: 12:00 AM
Inspection Type: Caisson Deck/Pole Barn
Inspection Code: 97
Outcome: Disapproved
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

- 1- Caisson have bend poured , Provide eng. letter
- 2- If rear deck is added and not no approved plans you need to obtain a deck permit for change to approved plans. No plans on site for inspection.