



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 13-07431  
Inspection Number: 03060120

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 130 FLOWERBURST DR HIGHLANDS RANCH  
**Job Type:** Building  
**Description:** RS - Basement  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 11/22/2013  
**Inspection Time:** 8:44 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Cancelled  
**Inspected By:** Brian Brown  
**Charge Reinspection Fee:** No