



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 13-08652

Inspection Number: 03063914

## Building Inspection Report

Code Reviewed Under: 2012 IBC

### Permit Information

Job Address: 8351 N RAMPART RANGE RD # C103, LITTLETON

Job Type: Building

Description: CM - Tenant Improvement

Scope of Work: New

### Inspection Details

Inspection Date: 12/18/2013

Inspection Time: 12:00 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Disapproved

Inspected By: Jim Dorsey

Charge Reinspection Fee: No

### Comments

fire wall: cant use cut in boxes

2. occ 73, will need ext em lights per 1006.3 IBC

3. appear to be lacking em illumination. provide photometric layout

removed wall demo is ok