Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 13-07264
Inspection Number: 03064054

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 9121 FOX FIRE DR HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 12/19/2013
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Rick Sugar
Charge Reinspection Fee: No

Comments

Guard strips in storage closet
Cover plate needed in mech rm gfci
Co\smoke outside of BR